PERMIT AMENDMENT NO. 7389-097-0061-S-06-1
ISSUANCE DATE: 9/20/2019

GEORGIA
DEPARTMENT OF NATURAL RESOURCES

ENVIRONMENTAL PROTECTION DIVISION

Air Quality – Permit Amendment

In accordance with The Georgia Air Quality Act, O.C.G.A. Section 12-9-1, et seq and the Rules, Chapter 391-3-1, adopted pursuant to or in effect under that Act, Permit No. 7389-097-0061-S-06-0 issued on June 19, 2019 to:

Facility Name:	**Google LLC.**
Facility Address:	**300 Riverside Parkway SW** **Lithia Springs, Georgia 30122 (Douglas County)**
Mailing Address:	**300 Riverside Parkway SW** **Lithia Springs, Georgia 30122**
Facility AIRS Number:	**04-13-097-00061**

for the following: **Operation of an electronic data center including the operation of emergency power generators for emergency standby operation. This Permit is issued for the purpose of establishing practically enforceable emission limitations such that the facility will not be considered a major source with respect to Title V of the Clean Air Act Amendments of 1990.**

is hereby amended as follows: To include the operating options of paragraphs 7 and 8 of Georgia State Rule 391-3-1-.02(2)(mmm) in Condition 2.6 of the permit.

Reason for Amendment: Application No. 27135 dated July 3, 2019

This Permit is further subject to and conditioned upon the terms, conditions, limitations, standards, or schedules contained in or specified on the attached 1 page(s).

This Permit Amendment is hereby made a part of Permit No. 7389-097-0061-S-06-0 and compliance herewith is hereby ordered. Except as amended hereby, the above referenced Permit remains in full force and effect.

STATE OF GEORGIA
CONSTITUTION
WISDOM
JUSTICE
MODERATION
1776

[Signed]

Richard E. Dunn, Director
Environmental Protection Division

2. Allowable Emissions

Modified Condition:

2.6 The Permittee shall limit the operation of each emergency generator to less than 500 operating hours during any consecutive twelve-month period for routine testing and maintenance, when electric power from the local utility is not available, or internal system failures. For any emergency generator exceeding 200 operating hours during the previous twelve months, operation for routine testing and maintenance during the months of May through September shall be limited to the hours between 10 p.m. to 4 a.m.
[391-3-1-.02(2)(mmm), 40 CFR 60.4211(f)(3) subsumed]